



**Henry County
Purchasing Department**
140 Henry Parkway, McDonough, GA 30253
Phone: 770-288-6027 Fax: 770-288-6047

Website: henrycounty-ga.com/purchasing

ADDENDUM #2

Issued June 14, 2019

Bid # 19-37

Panola Mountain Greenway Trail PATH
Georgia Department of Transportation (GDOT) PI #0010721
Opening: 3:00 PM, June 20, 2019

The following items take precedence over referenced portions of the documents for the above-named project and in executing a contract, will become a part thereof. Where any item in the documents is supplemented hereby, the original requirements will remain in effect. All supplemental conditions will be considered as added thereto. Where any original item is amended, voided or superseded hereby, the provisions of such items not so specifically amended, voided or superseded will remain in effect.

- 1. Question:** Is the Structural steel in Bridge 2 Painted or Unpainted? There are no notes or special provisions that discuss the finish of this steel. Bridge 3 has a Special Provision noting to use unpainted structural steel.

Answer: Revise Note 1 on Drawing NO. 35-0011 (Bridge No. 2, Bridge Sheet 5 of 12) to the following: "STRUCTURAL STEEL SHALL CONFORM TO ASTM A709 GRADE 50W, UNPAINTED."

This addendum must be signed and attached to bid proposal to acknowledge receipt of addendum.
Failure to acknowledge any addenda will result in a non-responsive bid.

Company's Name

Date

Authorized Representative's Name

Authorized Representative's Signature